



eurofins

# Confirmation

Eurofins Product Testing A/S confirms that a sample of a Multipurpose Construction Adhesives with the name

## Seal & Bond MS 60

supplied by

## Novatio International N.V.

showed low VOC contents in a test in as specified in LEED credit EQ 4.1 (adhesives and sealants).

VOC contents was below the limit value specified as 70 grams VOC minus water per liters for Multipurpose Construction Adhesives.

The test has been performed on 27. April 2010, see test report no. G01830B.

Volatiles content (incl. water) was determined by Eurofins.  
Water content was specified by manufacturer.  
Solids content was determined by Eurofins.

**With this confirmation, use of product Seal & Bond MS 60 may qualify for fulfillment of LEED credit EQ 4.1 (adhesives and sealants).**

---

11 May 2010

---

Thomas Neuhaus  
Head of product emission test centre

Eurofins Product Testing A/S  
Smedeskovvej 38  
DK 8464 Galten / Denmark

Tel +45 70 22 42 76  
Fax +45 70 22 42 75

[www.product-testing.eurofins.com](http://www.product-testing.eurofins.com)